

REPORT

Performance test on spacer dampers for a quad bundle of ACSR Bersimis

J-7777 / LMT-2013-09-09-056

June 11th to July 13th, 2015

Customer: ASBESCO (India) private Limited.

CONCLUSION

The following results were obtained with Asbesco spacer-dampers installed as per their recommendations on a quad bundle of ACSR Bersimis conductors with a nominal tensile load of 39 kN:

	Results	Requirements
Max. peak-to-peak bending amplitude at clamps	32 μm	< 359 μm
Max. RMS bending amplitude at clamps	5.8 μm	< 72 μm
Max. P-P displacement for subspan oscillations	126 mm	< 350 mm
Max. fY _{rms} for subspan oscillations in each subspan	26 mm/s	< 80 mm/s
Mean fY _{rms} value associated with a given wind sector	1.4 mm/s	< 70 mm/s

Every spacer damper was inspected at the end of the test and no displacement of the clamps along the conductor was noticed nor any loosening of components or damage to conductor or spacer damper components.

Consequently, the quad bundle spacer damper for conductor ACSR Bersimis, Asbesco drawing number ASD/Q-45/35-39/D and as per their recommended spacer damper distribution chart meets the entire requirement related to this test as per specification of Power Grid Corporation of India Ltd.

Prepared by:

losee Paradis, research scientist

Martine Gouin, test technician

Pierre Van Dyke, senior research scientist

Approved by:

Alain Naddau

Mechanical and Environmental Testing Laboratory Manager

Institut de recherche d'Hydro-Québec

SUMMARY

CUSTOMER'S NAME AND ADDRESS Asbesco (India) private Limited,

4, Ho-Chi-Minh Sarani, Kolkata, 700 071, India

Phone: +91 33 26531275 Fax: +91 33 26532895

CUSTOMER'S REPRESENTATIVE Mr. Christian Bernauer, General Manager Engg. & QC

EQUIPMENT TESTED Spacer damper for a bundle of four ACSR Bersimis

conductor, Asbesco drawing No ASD/Q-45/35-39/D

SPECIFICATION As per specification of Power Grid Corporation of

India Ltd. (see Appendix A)

CONDUCTOR ACSR Bersimis conductor

TENSILE LOAD IN EACH SUB-CONDUCTOR Nominal tension: 39 kN

SAFE BENDING AMPLITUDE [EPRI, 2009] $Y_b = 239 \mu m \text{ peak-to-peak}$

BUNDLE CONFIGURATION SPACING 457 mm quad bundle

LOCATION OF TESTS Hydro-Québec – IREQ

Mechanical and Environmental Testing Laboratory

Ligne Expérimentale de Varennes (LEV)

2100, chemin du Lac, Varennes, Québec, Canada,

J3X 1P7

DATE OF TESTS June 11th to July 13th, 2015

TEST PERSONNAL Test engineers: Josée Paradis, Jr Eng., M.Eng.

Pierre Van Dyke, Eng. M.A.Sc. Ph.D.

Test technician: Martine Gouin Test mechanic: Pierre Forest