

TEST REPORT

Test object: High voltage insulator set
Designation: 500kV double tension composite insulator set for quadruple conductor
Manufacturer: **ASBESCO (India) Private Limited**
1-A, K.B.R. Complex; 4 Ho-Chi-Minh Sarani; Kolkata 700071 INDIA
Tested for: **ASBESCO (India) Private Limited**
Date of tests: 30th June 2015
Project ID: NTL-37/2015
Order/Contract: W115427-001; 27th April 2015
Test specification: IEC 61467: 2008
Tests performed: The test object constructed in accordance with the description, drawings and photographs incorporated in this test report has been subjected to power arc tests with parameters of 31.5kA – 0.2s; 31.5kA – 0.2s; 31.5kA – 0.5s
Test results: The tested 500kV double tension composite insulator set for quadruple conductor withstood the effects of power arc tests in conditions assigned by the manufacturer and passed the mechanical failing load test with the prescribed load.

This Test Report has been issued by VEIKI-VNL Electric Large Laboratories Ltd. Testing Laboratory in accordance with above mentioned specification.

The Report applies only to the test object. The responsibility for conformity of any product having the same designations with that tested rests with the Manufacturer.

This Report comprises 17 sheets in total (13 numbered pages, 1 drawing, 3 oscillograms).


Only integral reproduction of this document is permitted without written permission from VEIKI-VNL Electric Large Laboratories Ltd. Testing Laboratory.


VEIKI-VNL Electric Large Laboratories Ltd. Testing Laboratory is an independent testing laboratory. Member of Short-circuit Testing Liaison (STL).


VEIKI-VNL Electric Large Laboratories Ltd. Testing Laboratory is accredited by NAT (Hungarian Accreditation Board) under registration number NAT-1-1251/2015.



Budapest,
27th August, 2015


Viktor Jáger
responsible for the test


László Tóth
supervised by


Dr. László Varga
managing director

1158 Budapest, Vaszgolyó u. 2-4., HUNGARY

E-mail: vn1@vn1.hu

www.vn1.hu

Phone: +36-1-417 3157

Fax: +36-1-417 3163